



# CITY OF ARANSAS PASS

## Notice of Drinking Water Monitoring and Reporting Violations

The Texas Commission on Environmental Quality (TCEQ) has notified the CITY OF ARANSAS PASS Water System PWS 2050015 that we have violated the monitoring and reporting requirements set forth in Chapter 30, Section 290, Subchapter F. We are required to properly disinfect water before distribution. We are required to maintain, and accept disinfection residuals within the distribution system. Additionally, we are required to monitor the chlorine disinfectant residual at various locations throughout the distribution system and report the results of that monitoring to TCEQ on a quarterly basis. Results of regular monitoring are an indicator of whether or not your drinking water is safe from microbial contamination. Although disinfectant residual levels were never in violation during the monitoring periods and the water was safe, this violation occurred during the period beginning January 1, 2014 through April 30, 2014. Reporting for disinfectant residual levels were not completed at certain instances during this time period and resulted in a violation. The problem has been corrected by updating and sending Disinfectant Residual Level Reports to TCEQ in the time intervals that are required. The City is also required to notify the public of the violation. This letter is the official notice. Please share this information with all people who drink this water, especially those who may not have received this notice directly.

Again, the water was safe during the time period above. The reports were not submitted during the proper time frame.

For further information contact: Cande Torres, Aransas Pass Utility Department at (361)-758-3111

Public Water System ID # 2050015